



TAP GEOMETRY

1. TAP TO BE MADE NO CLOSER THAN 12" FROM END OF JOINT LENGTH, & 4 FT. FROM MANHOLE.
2. THE HOLE FOR INSERTA-TEE SHALL BE MADE WITH A TAPPING MACHINE. THE HOLE SHALL BE CLEANLY MACHINED AND IF NECESSARY WORKED BY HAND TO ACCOMPLISH A TRUE AND NEAT OPENING FOR THE FITTING.
3. CONNECTIONS SHALL BE SECURED TO THE SEWER WITH AN APPROVED FACTORY FITTING OR INSERTA TEE IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
4. THE BELL END OF THE CONNECTION SHALL BE CAPPED OR PLUGGED TO PREVENT ENTRY AND OBSTRUCTION BY CONSTRUCTION MATERIALS AND GROUND WATER, AND LOCATION MARKED IN ACCORDANCE WITH STD. DWG 5-1.
5. ANY DAMAGED PIPE SHALL BE REPAIRED OR REPLACED AS DIRECTED BY THE INSPECTOR.
6. INSERTA-TEES MAY BE USED WHEN THE NOMINAL DIAMETER OF THE INSERTA-TEE IS LESS THAN 3/4 OF THE NOMINAL DIAMETER OF THE MAINLINE. ALL OTHER CONNECTIONS WILL REQUIRE CUT-IN WYE'S. (I.E. 6" INSERTA-TEE CAN ONLY BE USED IN MAINLINES 10" OR LARGER)
7. STD. WYE INSTALLATION DURING MAINLINE CONSTRUCTION SHALL CONFORM TO RECOMMENDED GEOMETRY



**ROGUE VALLEY
SEWER SERVICES**

136 WEST VILAS ROAD

CENTRAL POINT, OR.

**STANDARD WYE OR TEE
CONNECTION TO SEWER MAINS**

Rev.12/98
Rev.9/07

**STANDARD
DRAWING
NO.
5-2
DATE: 9/07**